



EC Conformity Declaration

Document No.: 3099
Month . Year: 11.03
Manufacturer: WAGO Kontakttechnik GmbH
Address: HansasträÙe 27
32423 Minden
Germany

Product designation: **Connecting terminal
for flexible conductors
Series 222**

The designated product conforms to the provisions of the following European directives:

Number: 73 / 23 / EG (Low Voltage Directive)
Text: Electrical Equipment designed for use within
certain voltage limits


The conformity of the designated products with the requirements of this directive is proven by the accordance with the relevant paragraphs of the following european standards:

EN 60998-1; 1993	Connecting devices for low-voltage circuits for household and similar purposes. Part 1: General requirements
EN 60998-2-2; 1993	Connecting devices for low-voltage circuits for household and similar purposes. Part 2-2: Particular requirements for connecting devices as separate entities with screwless clamping units.

Issuer: WAGO Kontakttechnik GmbH
HansasträÙe 27
32423 Minden
Germany

Place, date: Minden, November 3rd, 2003

Legally binding signature:


.....
W. Neumann
Technical Director

ENEC CERTIFICATE

Connecting devices as separate entities with screwless-type clamping units (EN 60998-2-2)

Product:	Terminal blocks
Manufacturer:	Wago Kontakttechnik GmbH, Hansastraße 27, Postfach 2880, D-32423 Minden, Germany
Production site:	Wago Kontakttechnik GmbH, Hansastraße 27, Postfach 2880, D-32423 Minden, Germany
Certificate holder:	Wago Kontakttechnik GmbH, Hansastraße 27, Postfach 2880, D-32423 Minden, Germany
Certified by request of:	Wago Kontakttechnik GmbH, Hansastraße 27, Postfach 2880, D-32423 Minden, Germany
Trademark:	WAGO
Model/Type ref.:	Series 222 (See Appendix)
Rated current or power:	32 A
Rated voltage:	450 Vac
Rated cross-section area:	0,5mm ² - 4,0 mm ²
Rated ambient temperature:	40°C
Proof tracking index (PTI)	175 V
Insulation Class:	-
Degree of protection:	IP00

Variants covered by this Certificate are specified in the attached appendix.
Detailed specification of the certified product(s) is listed in the appendix.

A sample of the product has been tested and found in conformity with EN 60998-2-2:93 and EN 60998-1:93 + A1:01, as shown in the Test Report with ref. No. 134401-01.

The manufacturer complies with the Production Surveillance Requirements.

Products included in this Certificate are allowed to carry the marks ENEC 15, UL International Demko A/S - as shown in annex 1.

This Certificate is only valid for products, which are identical to the certified product, and manufactured at the above mentioned production site(s).

UL International Demko A/S has to be informed in writing about any changes, in accordance with the "UL International Demko A/S Standard Terms and Conditions" for UL International Demko A/S services. This document contains 2 page(s).

Herlev, 27-03-2003


Kasper Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565



An Affiliate of
**Underwriters
Laboratories Inc.®**

APPENDIX TO ENEC CERTIFICATE N° 134401-01

The Certificate covers the following:

Terminal Blocks 0,5 – 4,0 mm ² , Series 222, Non universal				
Item-No.	Nos. Of poles	In all colours	Standard colour	Rated voltage [V]
222-4	222-4X2	X	Light-grey	450
222-4	222-4X3	X	Light-grey	450
222-4	222-4X4	X	Light-grey	450
222-4	222-4X5	X	Light-grey	450

Production Sites:

WAGO Kontakttechnik GmbH
Hansstrasse 27, D-32423 Minden
Germany.

WAGO Contact GmbH
Waldstrasse 1, D-99792 Berka/Wipper
Germany.

WAGO Contact SA
Zone Industrielle C, Case postale 168
CH-1564 Domdidier
Switzerland.

Herlev, 27-03-2003


Karina Christiansen
Certification Manager

UL International Demko A/S

Lyskaer 8, P.O. Box 514
DK-2730 Herlev, Denmark
Telephone: +45 44856565



An Affiliate of
**Underwriters
Laboratories Inc.**